



## Type Examination

No. BSI-LD-008

Issued to:

Dewhurst Plc  
Inverness Road  
Hounslow  
TW3 3LT  
United Kingdom

In respect of:

Landing door locking device model VL20



Product Services

on the basis of our examination under the requirements of Council Directive 95/16/EC, Annex V:A, The Lift Directive, as recorded in BSI Report No. 282/005130-70 dated 16 July 1999.

For and on behalf of the British Standards Institution, a Notified Body for the above Directive (Notified Body Number 0086):

David Ford, Managing Director, BSI Product Services.

First Issued: 16 July 1999

Issue 2 Date: 1 April 2009

Page: 1 of 2

Any modification to the design of this product will invalidate this EC Certificate and the Notified Body, number 0086, must be informed without delay.

## Type Examination

No. BSI-LD-008

This EC type-examination certificate is only valid when a landing door locking device model VL20 is installed to operate under the following conditions:

1. For use with horizontal sliding or hinged doors.
2. For use at a rated voltage and current of 240V 2.0A 50 Hz or 240V 1.0A dc.

**Manufacturing site:**

Dewhurst Hungary Kft.,  
Sóskút,  
Hungary

# Product Services

For and on behalf of the British Standards Institution, a Notified Body for the above Directive (Notified Body Number 0086):



David Ford, Managing Director, BSI Product Services.

First Issued: 16 July 1999

Issue 2 Date: 1 April 2008

Page: 2 of 2

*raising standards worldwide™*

**BSI**  
Product Services